

**AMENDMENT #1**  
**Questions & Answers for RFx 3140004572**  
**Request for Quotes - Wastewater Plant Inspection and Service Operations**  
RFQ Issue Date: May 19, 2026

The Mississippi Department of Corrections is issuing Amendment No. 1, Request for Quotes for Wastewater Plant Inspections and Service Operations at Quitman County Work Center (QCWC), dated May 19, 2026. Amendment 1 provides responses to questions received after the publishing of this solicitation.

#	Question	Answer
1.	For 3.9 & 3.11 both indicates the requirement of quarterly sampling. The facility's permit (MS00043281) only requires an annual (once a year) sampling for majority of the permit parameters except for the Flow and Total Chlorine Residual (TCR) which are weekly. Does the facility still want to collect quarterly sampling even though is only required once a year?	<b>Yes, quarterly sampling will be required. The task and cost will be the responsibility of the operator.</b>
2.	By the description in the scope of work in 3.3 that it is a lagoon system that will be operated. Also, with the need of a class II operator, aeration is a part of the treatment. Where is the facility located, are there picture of the facility, and will the facility be able visited before submission of the bid?	<b>3.3 states that the “The Bidder shall provide runtime sheets to calculate monthly flow.” The facility has a package plant and not a lagoon. No site visits will be scheduled. The address is 201 B Camp House Road, Lambert, MS 38643 and the GPS coordinates are 34.1542347, -90.2762873 per google maps. Pictures are available in Appendix A.</b>
3.	For facility's Total Chlorine Residual (TCR) the permit indicates a permit limit of 0.011 mg/L (Maximum Monthly Average) and 0.019 mg/L (Daily Maximum). Does the facility use chlorine gas for chlorination/disinfection and sulfur dioxide gas for the de-chlorination or chlorine and de-chlorination tablets?  Is the facility responsible for providing those chemicals?	<b>The package plant uses chlorine and de-chlorination tablets.</b>  <b>No. The cost will be the responsibility of the operator.</b>
<b>***END OF QUESTIONS AND ANSWERS***</b>		

In the event that any provision of this first amendment conflicts in whole or in part with any of the terms, conditions, or specifications of the RFX, the provisions of this first amendment will control. The effective date of this amendment is May 28, 2026. All other terms, conditions, and specifications of this solicitation remain unchanged.

Please sign the acknowledgment page and return it acknowledging your receipt of this change to the RFQ titled Wastewater Plant Inspections and Service Operations at Quitman County Work Center (QCWC). This form should be included with your submission of quote that is to be received on or before Wednesday, June 10, 2026 at 2:00 pm, CST.

---

**Acknowledge Receipt of Amendment #1**

**Receipt for Amendment #1** \_\_\_\_\_  
Signature

\_\_\_\_\_  
**Printed Name**

\_\_\_\_\_  
**Date**

\_\_\_\_\_  
**Company Name**

\_\_\_\_\_  
**Title**

**APPENDIX A**  
**Pictures of Wastewater Plant at Quitman County Work Center**  
**(QCWC)**



