APPENDIX B

205 West Cunningham Avenue P.O. Box 957 Terry, Ms. 39170
Phone: 601-878-6701 Fax: 601-878-6720
E Mail: jtodd@capitalairbalance.com

AIR CHANGE DATA SHEET

Date: 04/21/22
Job Name: East Mississippi Correctional Facility
Page: 1 OF 1
Location: Meridian, MS

Room No.	Actual Sup. CFM	Actual Exh. CFM	Room Size	Air Changes Required	Air Changes Actual	Pressurization Required	Pressurization Actual
Ante 515	60	-0-	361	10	10.0	O	N
150 516	35	200	745	12	16.1	N	N
150 517	25	200	695	12	17.3	N	N

P=POSITIVE N=NEGATIVE O=OPTIONAL E=EQUAL

RED signifies "Did not meet room requirements"

205 West Cunningham Avenue P.O. Box 957 Terry, Ms. 39170
Phone: 601-878-6701 Fax: 601-878-6720
E Mail: jtodd@capitalairbalance.com

AIR CHANGE DATA SHEET

Date: 11/03/22
Page: 1 OF 1
Location: Pearl, MS

Job Name: Central Mississippi Correctional Facility

Room No.	Actual Sup. CFM	Actual Exh. CFM	Room Size	Air Changes Required	Air Changes Actual	Pressurization Required	Pressurization Actual
Isolation Room 1	102	220	2152	6	6.1	N	N
Isolation Room 2	139	255	2030	6	7.5	N	N
Ante Room	160	60	1168	10	8.2	O	P

Capital Air Balance, Inc. ASSOCIATED AIR BALANCE COUNCIL AABC TGE-80-95-13 John D Todd

P=POSITIVE N=NEGATIVE O=OPTIONAL E=EQUAL

RED signifies "Did not meet room requirements"

205 West Cunningham Avenue P.O. Box 957 Terry, Ms. 39170
Phone: 601-878-6701 Fax: 601-878-6720
E Mail: jtodd@capitalairbalance.com

AIR CHANGE DATA SHEET

Date: 07/18/20022
Page: 1 OF 1
Location: Parchman, MS

Job Name: Mississippi State Penitentiary

Room No.	Actual Sup. CFM	Actual Exh. CFM	Room Size	Air Changes		Pressurization	
				Required	Actual	Required	Actual
Isolation 100	140	440	1559	12	16.9	N	N
Antre	70	27	580	10	7.2	O	N
Isolation 102	100	410	1559	12	15.7	N	N

P=POSITIVE N=NEGATIVE O=OPTIONAL E=EQUAL

RED signifies "Did not meet room requirements"

205 West Cunningham Avenue P.O. Box 957 Terry, Ms. 39170
Phone: 601-878-6701 Fax: 601-878-6720
E Mail: jtodd@capitalairbalance.com

AIR CHANGE DATA SHEET

Date: 12/19/22
Page: 1 OF 1
Location: Leakesville, MS

Job Name: South Mississippi Correctional Institution

Room No.	Actual Sup. CFM	Actual Exh. CFM	Room Size	Air Changes		Pressurization	
				Required	Actual	Required	Actual
Isolation Room - 1	160	270	2075	6	7.8	N	N
Isolation Room - 2	265	425	2075	6	12.2	N	N
Ante	30	185	1050	10	10.5	O	N

Capital Air Balance, Inc. ASSOCIATED AIR BALANCE COUNCIL AABC RBE - 80-05-12 John D. Todd

I [illegible]OSITIVE N=NEGATIVE O=OPTIONAL E=EQUAL

RED signifies "Did not meet room requirements"